

Er. G. RAJA, M.E (Struc). C.Eng.,
Regd. Structural Engineer Grade - II
Chartered Engineer & Regd. Valuer
Panel Engineer Class 1A Erode Dt.

LOGU AND CO
ENGINEERING AND CONSTRUCTION



133/1, PETTAI PERUMAL KOVIL STREET.
OPP. MANGALAM SILKS, THERVEETHI.
ANTHIYUR - 638501. GSTIN : 33AAJFL8281H1Z2
Mobile : 9943344254 - E-Mail : g.raja.be@gmail.com

File No: LOC/ANT/020

Date: 16/04/2025

CERTIFICATE OF STABILITY
STATEMENT ACCOMPANYING - FORM A

1. Name of the Building : AGARAM EDUCATIONAL AND CHARITABLE TRUST
2. Door Number of Building : D.NO:104
3. Location (Street Number, Ward Number, Name of place, i.e., Corporation/ Municipality/Township : S.F NO:140/2B,141/1B2,
: PACHAMPALAYAM VILLAGE,
ANTHIYUR,
ERODE District .638-314.
4. Year of Construction : 2023.
5. Approximate cost of construction : Rs.4.06 Crores/-
6. Purpose for which the building is being used or proposed to be used : SCHOOL BUILDING
Class room,Activity room, Library & Toilets
7. Purpose for which the building has either to been used : SCHOOL BUILDING
Class room,Activity room, Library & Toilets
8. Details of construction of the building (particulars of the foundation soil, specification of the various parts under
(1) Foundation : R.C.C Framed Structures,
(2) Basement : R.C.C footings
(3) Superstructure : R.C.C Column with Brick work in Cement Mortar
(4) Floor and roof are to be given : R.C.C flat roofing with beam&Vitrified Tiles
9. Period for which licence is required effect from 16/04/2025 to 15/04/2028
10. No of Persons to be accomodated (including all): 800

Date: 16/04/2025

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or a portion of the building originally is changed or altered subsequently.

Date: 16/04/2025

PRINCIPAL

Agaram Global School,
Pachampalayam Pudur,
Pachampalayam, Anthiyur (Tk),
Erode (Dt) - 638314.

Signature of the owner of the building

For Agaram Global School

Correspondent

FORM - B

(Form of certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred in rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.)

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features:

1.Foundation:-

- | | | |
|-------|--|----------------------------|
| (i) | Depth below ground level | : 2.10M |
| (ii) | Nature of soil met with at foundation level | : Soft Disintegrated Rock. |
| (iii) | Pressure at foundation | : 20.06 T / Sqm |
| (iv) | Probable safe bearing capacity of the strata met with at foundation. | : 30.00 T / Sqm |


2.Superstructure:-

- | | | |
|------|--|---|
| (v) | Maximum stress in the most critical section of masonry and concrete. | : Masonry - 40T/Sqm
Concrete - 400/Kgs/Sqm |
| (vi) | Nature of masonry and concrete and it's safe permissible stress. | : Masonry - 45T/Sqm
Concrete - 450/Kgs/Sqm |

The structural soundness of the building has been verified by me with reference to I.S.I. loading standards 875 (Latest version) and other relevant Indian Standards Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period of 3 Years


Effect from 16/04/2025 to 15/04/2028.

Date: 16/04/2025




PRINCIPAL

Agaram Global School,
Pachampalayam Pudur,
Pachampalayam, Anthiyur (Tk),
Erode (Dt) - 638 314.


Signature of the Engineer.
ER. G. RAJA, M.E. (Struc), C. Eng.,
Panel Engineer Class - IA Erode District,
R.Dis.(E)/136576/2022/C2 DL21.10.2023
Mob : +91 99433 44254


For Agaram Global School



Correspondent

ANNEXURE TO FORM - B
STATEMENT TO ACCOMPANY THE CERTIFICATE OF
STRUCTURAL SOUNDNESS


1. Location of the Building D.No, Street and Name of place : AGARAM GLOBAL SCHOOL
S.F NO:140/2B,141/1B2,
: 104, PACHAMPALAYAM
ANTHIYUR,
ERODE District-638-314
: 2 Years.
- Age of Building : GF+FF+SF.
2. Number of Storey's
3. Short description of Structures - : R.C.C Framed Structure.
Steel - RCC framed of load bearing masonry
4. Purpose for which the building is : SCHOOL BUILDING
certified for used sound : Class room, Activity room, Library & Toilets
5. The period for which the building will be : 16/04/2025 to 15/04/2028
structurally sound
6. Number of persons to be accommodated : 800 persons
(including all)
7. Area Of Construction :
 - > RCC Roof Ground Floor : 14542.00 Sq.Ft
 - > RCC Roof First Floor : 13542.00 Sq.Ft
 - > RCC Roof Second Floor : 13542.00 Sq.Ft


PRINCIPAL


Agaram Global School,
Pachampalayam Pudur,
Pachampalayam, Anthiyur (Tk),
Erode (Dt) - 638 314.

For Agaram Global School

: 41626.00 Sq.Ft


Correspondent

Date: 16/04/2025


Engineer
Panel Engineer Class - IA Erode District,
R. Dis. (E)/135575/2022/C2 Dt. 21.10.2023
Mob : +91 99433 44254

FORM - C

[Form of certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act, 1965(Tamil Nadu Act XIII of 1965) referred to in rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966.]

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features:


1.Foundation:-

- (i) Depth below ground level : 2.10M
- (ii) Nature of soil met with at foundation level : Soft Disintegrated Rock.
- (iii)
- (iv) Pressure at foundation : 20.06 T / Sqm
- (v) Portable safe bearing capacity
of the strata met with at foundation : 30.00 T / Sqm

2.Superstructure:-


- (vi) Maximum stress in the most critical
section of masonry and concrete : Masonry - 40T/Sqm
Concrete - 400/Kgs/Sqm
- (vii) Nature of masonry and concrete
and it's safe permissible stress : Masonry - 45T/Sqm
Concrete - 450/Kgs/Sqm


The structural soundness of the building has been verified by me with reference to I.S.I. loading standards 875 (Latest version) and other relevant Indian Standards Code of Practice and declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period of 3 Years effect from 16/04/2025 to 15/04/2028.


PRINCIPAL

For Agaram Global School, Agaram Global School,
Pachampalayam Pudur,
Pachampalayam, Anthiyur (Tk),
Erode (Dt) - 638314.

Dated : 16.04.2025


Correspondent


Signature of the Engineer
Er. G. RAJA, M.E. (Struc), C. Eng.,
Panel Engineer Class - IA Erode District,
R Dis. (E)/135575/2022/C2 Dt. 21.10.2023
Mob : +91 99433 44254

FORM 'E'
THE CERTIFICATE OF STRUCTURAL SOUNDNESS.

1. Location of the building –Door number,
street and name of the place

Survey No

: AGARAM GLOBAL SCHOOL
S.F NO:140/2B,141/1B2,
: 104, PACHAMPALAYAM
ANTHIYUR,
ERODE District -638-314.

2. Age of building

: 2 Years.

3. The value of the building at the current rates

: Rs.4.06 Crores-

4. Number of storey

: GF+FF+SF

5. Short description of structures-Steel-
RCC framed of load bearing

: RCC Framed Structure.

6. Purpose for which the building
is certified for use.

: SCHOOL BUILDING
Class room,Activity room, Library & Toilets

7. The period for which the building
will be structurally sound

: 16/04/2025 to 15/04/2028

8. Number of persons to be accommodated.

: 800 Persons

9. Area Of Construction

- RCC Roof Ground Floor
- RCC Roof First Floor
- RCC Roof Second Floor

: 14542.00 Sq.Ft
: 13542.00 Sq.Ft
: 13542.00 Sq.Ft

Total Area

: 41626.00Sq.Ft

Dated: 16/04/2023

PRINCIPAL

Agaram Global School,
Pachampalayam Pudur,
Pachampalayam, Anthiyur (Tk),
Erode (Dt) -638 314.


Signature of the Engineer
Er. G. RAJA, M.E. (Struc), C. Eng.,

Panel Engineer Class - IA Erode District,
R.Dis.(E)/135575/2022/C2 Dt.21.10.2023
Mob : +91 99433 44254

For Agaram Global School


Correspondent

DATE: 11/24/2001		TIME: 11:24	
1	1000	1000	1000
2	1000	1000	1000
3	1000	1000	1000
4	1000	1000	1000
5	1000	1000	1000
6	1000	1000	1000
7	1000	1000	1000
8	1000	1000	1000
9	1000	1000	1000
10	1000	1000	1000
11	1000	1000	1000
12	1000	1000	1000
13	1000	1000	1000
14	1000	1000	1000
15	1000	1000	1000
16	1000	1000	1000
17	1000	1000	1000
18	1000	1000	1000
19	1000	1000	1000
20	1000	1000	1000
21	1000	1000	1000
22	1000	1000	1000
23	1000	1000	1000
24	1000	1000	1000
25	1000	1000	1000
26	1000	1000	1000
27	1000	1000	1000
28	1000	1000	1000
29	1000	1000	1000
30	1000	1000	1000
31	1000	1000	1000
32	1000	1000	1000
33	1000	1000	1000
34	1000	1000	1000
35	1000	1000	1000
36	1000	1000	1000
37	1000	1000	1000
38	1000	1000	1000
39	1000	1000	1000
40	1000	1000	1000
41	1000	1000	1000
42	1000	1000	1000
43	1000	1000	1000
44	1000	1000	1000
45	1000	1000	1000
46	1000	1000	1000
47	1000	1000	1000
48	1000	1000	1000
49	1000	1000	1000
50	1000	1000	1000
51	1000	1000	1000
52	1000	1000	1000
53	1000	1000	1000
54	1000	1000	1000
55	1000	1000	1000
56	1000	1000	1000
57	1000	1000	1000
58	1000	1000	1000
59	1000	1000	1000
60	1000	1000	1000
61	1000	1000	1000
62	1000	1000	1000
63	1000	1000	1000
64	1000	1000	1000
65	1000	1000	1000
66	1000	1000	1000
67	1000	1000	1000
68	1000	1000	1000
69	1000	1000	1000
70	1000	1000	1000
71	1000	1000	1000
72	1000	1000	1000
73	1000	1000	1000
74	1000	1000	1000
75	1000	1000	1000
76	1000	1000	1000
77	1000	1000	1000
78	1000	1000	1000
79	1000	1000	1000
80	1000	1000	1000
81	1000	1000	1000
82	1000	1000	1000
83	1000	1000	1000
84	1000	1000	1000
85	1000	1000	1000
86	1000	1000	1000
87	1000	1000	1000
88	1000	1000	1000
89	1000	1000	1000
90	1000	1000	1000</



FRONT ELEVATION

SECTION C14-3



FIRST FLOOR PLAN

TYPE OF PROJECT

Dr. O. S. A. A. (M. F. (Struct.) C. Eng.,
Panel Engineer Class - A Erode District,
R.Ds.(E)/136678/2022/C2 Dt.21.10.2023
Mob : +91 99433 44254

Proceedings of the District Collector, Erode District
Present: Thiru. Raja Gopal Sunkara, I.A.S.,

R.Dis.(E)135575/2022/C2

Date: 21.10.2023

- Subj: Tamil Nadu Public Buildings and Licensing Act, 1965 - Erode District - Anthiyur Taluk - Thavittupalayam - 22/2, Gandhiji Street Cross 4- Thiru.G.Raja - Inclusion of his name in the panel of Private Practicing Engineers Erode District - orders issued - Regarding.
- Ref: 1. G.O.Ms.No.43, Municipal Administration & Water Supply(MA4) Department, dated:17.02.2011.
2. Application received from Thiru. G.Raja dated 01.09.2022.
3. Erode, Superintending Engineer, PWD, Buildings (C&M) Circle, letter No.DB/DO/F.Panel of Engineers/2023/4M, dated: 06.01.2023.
4. Chennai, Engineer-in-Chief & Chief Engineer(General), Public Works Department Letter No. AEE/T10/BOE004-6/2023, Dated:06.09.2023.

>><<

ORDER:

The Engineer-in-Chief & Chief Engineer (General) Chennai Region, Public Works Department, Chennai in the reference 4th cited has stated that the Board Of Engineers In Its 4th Board Of Engineers (TNPWD) Meeting has approved the name of Er.G.Raja (D.O.B:08.01.1991) for inclusion and registering in the panel of Private Practicing Engineer under Class IA (Class One A) category (Buildings, the cost of which exceeds Rs.50 Lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated 17.02.2011 in Erode District.

Accordingly, the Name of Er.G.Raja, is hereby ordered to be included in the panel of Private Practicing Engineer under Class IA (Class One A) category (Buildings, the cost of which exceeds Rs.50 Lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated 17.02.2011 in Erode District and his name is entered in SL.No.03/2023 In the register of panel of Private Practicing Engineer maintained in this office.

(Sd) Raja Gopal Sunkara
District Collector
Erode District

For District Collector
Personal Assistant to
Collector(General),
Erode District.

// True Copy By order //

PRINCIPAL

Agaram Global School,
Pachampalayam Pudur,
Pachampalayam, Anthiyur (T)
Erode (Dt) - 638 314.

For Agaram Global School

To:

Thiru.G.Raja
S/O.Govindan,
22/2, Gandhiji street cross - 4
Thavittupalayam, Anthiyur, Erode district-638 501

25.10.23